# 1492-IFM20F-F120A-2 1492-RIFM20F-F120A-2


Fusible Extra Terminals with 120V AC/DC Blown Fuse Indicators



## Application Notes

- **1. Compatibility** To ensure proper operation with the I/O module, do **not** exceed the voltage and current ratings of the IFM.
- **2. Wiring** Refer to the Label Section on page 174. For Field-Side Wiring Diagrams, refer to the Wiring System web site information on page 200.
- **3. Fusing** Fuse holders are included with the IFM. Fuses (5 x 20 mm) are not included.
- 4. Isolation The power bus, fuse clips, and blown fuse indicators are isolated into two groups of 10 terminals (eight fuse clips and blown fuse indicators). This allows each group of input devices to reference a different power source.
- **5. Dimensions** Refer to page 159.

#### **Pinout**



### 1492-IFM20F-F240-2


Fusible Extra Terminals with 240V AC/DC Blown Fuse Indicators



Application Notes

- **1. Compatibility** To ensure proper operation with the I/O module, do **not** exceed the voltage and current ratings of the IFM.
- 2. Wiring Refer to the Label Section on page 174. For Field-Side Wiring Diagrams, refer to the Wiring System web site information on page 200.
- **3. Fusing** Fuse holders are included with the IFM. Fuses (5 x 20 mm) are not included.
- **4. Isolation** The power bus, fuse clips, and blown fuse indicators are isolated into two groups of 10 terminals (eight fuse clips and blown fuse indicators). This allows each group of output devices to reference a different power source.
- **5. Dimensions** Refer to page 160.

#### **Pinout**



For updated page numbers refer to:
Publication 1492-TD008C-EN-P - September 2005